



NOTES:

1. THE TOTAL VOLUME OF CHEMICALS PROPOSED TO BE STORED ON SITE IS 758 GALLONS. REFERENCE MATERIAL LIST OF CHEMICALS.
2. ALL FLOORS IN BUILDING SLOPED TO DRAINS TO CONTAIN HAZARDOUS MATERIALS IN TIGHT TANKS. TIGHT TANKS DESIGNED TO HOLD ALL CHEMICALS AND SPRINKLER DISCHARGE AS PER FIRE DEPARTMENT.
3. BUILDINGS WILL BE HEATED WITH NATURAL GAS.
4. ALL PAVED SITE AREAS WILL BE BERMED TO CAPTURE RUNOFF.
5. CONSTRUCTION MATERIALS STORED ON SITE TO BE COVERED.
6. ALL FLAMMABLES WILL BE STORED IN FLAMMABLE STORAGE CABINETS.

AMOUNT OF FLAMMABLES IN FLAMMABLE STORAGE CABINETS:
32 GALLONS

AMOUNT OF STORAGE PROVIDED IN FLAMMABLE STORAGE CABINETS:
(2) CABINETS X 60 GALLON CAPACITY = **120 GALLONS**

AMOUNT OF NON-FLAMMABLES IN HAZARDOUS MATERIAL STORAGE CABINETS:
22 GALLONS

AMOUNT OF STORAGE PROVIDED IN HAZARDOUS STORAGE CABINETS:
(2) CABINETS X 60 GALLON CAPACITY = **120 GALLONS**

